PLATE 1

CITY OF GRANTS PASS

Water System Map

February 2016

Murray, Smith & Associates, Inc.
Engineers/Planners
121 S.W. Salmon, Suite 900
Portland, Oregon 97204
PHONE 503-225-9010
FAX 503-225-9022

DRAFT

15-1634

SEE NORTH VALLEY INSET

NORTH VALLEY INSET

GRANTS PASS AIRPORT

INSET SCALE: 1"=2,000'

RESERVOIR NO. 15
CAP: 1.3 MG
OE: 1403 FT

NORTH VALLEY PUMP STATION

RESERVOIR NO. 6
CAP: 3.5 MG
OE: 1240 FT

RESERVOIR NO. 8
CAP: 2 MG
OE: 1370 FT

Zone 3

CHAMPION PUMP STATION

LAUREL RIDGE PUMP STATION

Zone 2

Zone 4LR

Zone 4

RESERVOIR NO. 13
CAP: 0.08 MG
OE: 1455 FT

STARLITE PUMP STATION

STARLITE PRV

Zone 3S

Zone 2A

9TH & SAVAGE PRV

BEACON DRIVE PRV

HEFLEY PUMP STATION

RESERVOIR NO. 4
CAP: 0.75 MG
OE: 1240 FT

Zone 3B

RESERVOIR NO. 3
CAP: 5 MG
OE: 1108.5 FT

MANZANITA PRV

LAWNRIDGE PUMP STATION

RESERVOIR NO. 5
CAP: 3.5 MG
OE: 1108.5 FT

MADRONE PUMP STATION

Rogue River

Zone 1

WTP

WATER TREATMENT PLANT

Zone 2HT

HILLTOP PUMP STATION

Zone 2HK

HARBECK PUMP STATION

ROGUE COMMUNITY COLLEGE (RCC)

RESERVOIR NO. 11
CAP: 4.5 MG
OE: 1108.5 FT

NEW HOPE PUMP STATION

MEADOW WOOD HIGH PUMP STATION

Zone 2MW

Zone 3MW

Zone 3P

PANORAMIC PUMP STATION

Zone 3WX

WILLIAMS CROSSING PUMP STATION

Zone 2NH

N

1,000 0 1,000

SCALE: 1" = 1,000'

LEGEND

- EXISTING RESERVOIR
- EXISTING PUMP STATION
- EXISTING PRESSURE REDUCING VALVE (PRV)
- 8" EXISTING WATER MAIN (DIAMETER INDICATED IN INCHES)
- EXISTING WATER SERVICE AREA
- CITY LIMITS
- URBAN GROWTH BOUNDARY (UGB)
- 1000 50-FOOT CONTOUR (ELEVATION IN FEET)
- RAILROAD

I:G:\PDX_Projects\15\1634 - Grants Pass WDSMP\GIS\MXD\15-1634-4100-OR_PLATE 1.mxd 2/16/2016 11:48:04 AM DKH