

ADDENDUM NO. 1

to **CONTRACT DOCUMENTS** for

Fruitdale Creek – Hamilton Lane Trail
Project No. TR4719
Grants Pass, Oregon

To All Plan Holders:

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the construction of the Fruitdale Creek - Hamilton Lane Trail, Project No. TR4719, as fully and completely as if the same were fully set forth therein:

1. GENERAL CLARIFICATIONS:

- **Pressure Treated Lumber:**
 - ACQ pressure treated lumber will be allowed as an acceptable replacement for AZCA.

- **Section 330 - Embankment basis payment:**
 - Bid Item #7 is meant to be removal of existing embankment. This material is meant to be reused on this project after asphalt and organic material have been removed.

- **Sheet C4.0 Division 05 – Metals note 1:**
 - The fabrication shop does not need to be AISC certified. The welders will need to be AWS certified and certifications of all welders shall be submitted to the engineer for review prior to construction.

- **GPID Canal Temporary Water Management:**
 - Note #7 on sheet C0.2 was intended for reference only and is to be adjusted & designed for anticipated conditions expected during the scheduled construction season.

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 1 by signing in the space provided and submitting the signed Addendum with the bid. Bids submitted without this Addendum will be considered irregular and may not be accepted.

RECEIPT OF THIS ADDENDUM IS ACKNOWLEDGED AND CONDITIONS ARE HEREBY AGREED TO

THIS ____ DAY OF _____ 2016.

Bidder's Name (Company)

BY: _____
(Signature)

END OF ADDENDUM NO. 1