



NOTES:

AN ENCROACHMENT PERMIT IS REQUIRED FOR ALL WORK WITHIN THE RIGHT-OF-WAY & SHALL BE PERFORMED BY A LICENSED PLUMBER OR CONTRACTOR, CURRENTLY PRE-QUALIFIED WITH THE CITY OF GRANTS PASS.

A WHITE TOP METAL FENCE POST SHALL BE PLACED AT THE LATERAL END, WITH 12" MIN. PROJECTING ABOVE THE GROUND LINE. 2 OR MORE METAL FENCE POSTS WIRED TOGETHER MAY BE REQUIRED FOR DEEP LATERALS.

WHEN LATERALS ARE CONNECTED TO AN EXISTING MAIN, THE MAIN SHALL BE MACHINE CORED AND AN APPROVED SADDLE INSTALLED.

LATERALS THAT ARE TUNNELED OR TRENCHED UNDER EXISTING CURB AND GUTTER OR OTHER UTILITIES SHALL BE BACKFILLED IN THAT AREA WITH A ONE (1) SACK CEMENT SAND SLURRY MIX. (SEE GPSD #107.)

AN "S" SHALL BE STAMPED IN TOP OF NEW CURB WHERE LATERAL CROSSES UNDER CURB.

A 45° WYE SECTION SHALL BE INSTALLED AT THE MAIN FOR TESTING OF LATERALS TAPPED INTO EXISTING MAIN.

TRENCHES SHALL NOT BE BACKFILLED UNTIL APPROVED BY ENGINEER. SEE GPSD #107.

NON-METALLIC SERVICES SHALL BE ENTWINED (MIN. 3 TURNS) WITH 18 GAUGE, INSULATED COPPER WIRE, GREEN IN COLOR, FOR THE FULL LENGTH WITH THE END LEFT ABOVE FINISHED GRADE.

ALL SANITARY SEWER SERVICES SHALL EXTEND THREE (3) FT. BEYOND R/W LINE. IF PUE EXISTS, EXTEND THREE (3) FT. BEYOND INTERIOR EASEMENT LINE.

NOTE: IF FACTORY TEE IS USED IN EXISTING MAIN, THE USE OF ROMAC TYPE SS1 or SS2 COUPLING IS REQUIRED.

NO.	DATE	INITIAL	REVISIONS	CITY OF GRANTS PASS ENGINEERING DIVISION		
3	7/97	FMS	UPDATE			
4	8/04	FMS	SEWER STD DWG UPDATE	LATERAL CONNECTION FOR EXISTING MAIN		
5	3/13	FMS	SEWER STD DWG UPDATE			
DESIGN: STAFF			DRAWN: SLN	APPROVED: DAP	SCALE: NONE	DWG. NO. 306