



- NOTES**
1. INSTALL 1/2" GALV. WIRE MESH OVER END OF BLOW-OFF IN UNIMPROVED AREAS
  2. THRUST RODS AND/OR REBAR EXPOSED TO SOIL SHALL BE ZINC COATED
  3. ALL VALVES WITH OPERATING NUTS MORE THAN 24" DEEP SHALL BE PROVIDED WITH OPERATOR EXTENSIONS PER GPSD #217

NO.	DATE	INITIAL	REVISIONS
4	2/02	FMS	REVISIONS
5	2/05	FMS	STD. DWG. UPDATE
6	12/10	GLV	2-1/2" VALVES

DESIGN: STAFF    DRAWN: FMS    APPROVED: DAP

CITY OF GRANTS PASS  
ENGINEERING DIVISION

2" BLOW-OFF ASS'Y

SCALE: NONE    DWG. NO. 205