



- NOTES**
- METER BOX TO BE FLUSH WITH FINISHED GRADE.
  - EXPOSED STEEL PIPE AND ANCHOR BOLTS TO BE PRIMERED AND PAINTED WITH 2 COATS OF 0063 SCHOOL BUS YELLOW ENAMEL.
  - CONCRETE SHALL BE COMMERCIAL GRADE CLASS 3300 PSI, 1 1/2" MAX. AGGREGATE PER 2002 ODOT/APWA STANDARD SPECIFICATIONS.
  - FITTINGS ON THE "LIVE" SIDE OF THE AIR RELEASE VALVE SHALL BE BRASS.
  - FITTINGS ON THE INACTIVE SIDE OF THE VALVE MAY BE GALVANIZED.
  - GATE VALVE BELOW COMBINATION AIR RELEASE MAY BE INSTALLED VERTICALLY OR HORIZONTALLY DEPENDENT ON DEPTH.
  - IF SIDEWALKS ARE NOT INSTALLED BUT THERE IS CURB & GUTTER, INSTALL CONCRETE PAD 5' BEHIND CURB TO ALLOW FOR FUTURE SIDEWALK INSTALLATION.
  - ACTIVE LINE BETWEEN MAIN AND ARV SHALL NOT EXTEND BEHIND SIDEWALK AND SHALL BE AS SHORT AS POSSIBLE.
  - VENT TO BE LOCATED BEHIND SIDEWALK AS CLOSE AS POSSIBLE TO COMBINATION VALVE.
  - CENTER VALVE IN BOX.
  - STACKED BOXES SHALL FIT SNUGLY, PERPENDICULAR TO THE CURB, WITH NO GAPS.

NO.	DATE	INITIAL	REVISIONS
7	1/04	FMS	NOTE 7
8	2/05	FMS	WATER STD DWG UPDATE
9	12/10	GLV	WATER STD DWG UPDATE

  

DESIGN: STAFF	DRAWN: FMS	APPROVED: DAP
---------------	------------	---------------

  

CITY OF GRANTS PASS ENGINEERING DIVISION	SCALE: NONE	DWG. NO. 206
---	-------------	--------------