

**ADDENDUM NO. 1**

to **CONTRACT DOCUMENTS** for

Riverside Park Pavilion and Spray Park  
Project No. LB6316/LB6342  
Grants Pass, Oregon

To All Plan Holders:

The following clarifications, changes, additions, and/or deletions are hereby made a part of the Contract Documents for the construction of the Riverside Park Pavilion and Spray Park, Project No. LB6316/LB6342, as fully and completely as if the same were fully set forth therein:

**1. CLARIFICATIONS...**

- **A plumber will need to install the Spray Park water service connection between the existing service tap and the double check valve. The general/site contractor can install the remaining water lines beyond the double check valve location.**
- **An electrician must run the electrical conduits within the Pavilion structure from the existing service panel to the canopy columns.**
- **The general/site contractor can run the drainage lines from the Spray Park to the storm drain outlet.**
- **All inspections will be called in through the City of Grants Pass Building Department.**
- **The Spray Park sequencing controller (Keyed Note 27/C1.0) will be located in the pre-fabricated manifold enclosure box and not in the existing bathroom as shown in the plans. The electrical connection will still be located in the existing bathroom structure/panel.**
- **The tidal barrel fill valve/line will be located between the PRV and distribution manifold.**

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 1 by signing in the space provided and submitting the signed Addendum with the bid. Bids submitted without this Addendum will be considered irregular and may not be accepted.

RECEIPT OF THIS ADDENDUM IS ACKNOWLEDGED AND CONDITIONS ARE HEREBY AGREED TO  
THIS \_\_\_\_ DAY OF \_\_\_\_\_ 2018.

\_\_\_\_\_  
Bidder's Name (Company)

BY: \_\_\_\_\_  
(Signature)

**END OF ADDENDUM NO. 1**