



General Notes:

1. An encroachment permit is required for all work within the right-of-way & shall be performed by a licensed plumber or contractor, currently pre-qualified with the City of Grants Pass.
2. A white top metal fence post shall be placed at the lateral end, with 60" min. projecting above the ground line. Two or more metal fence posts wired together may be required for deep laterals.
3. On new construction, only manufactured tees of the same material as the main shall be used.
4. All fittings shall be gasketed joints, no glued fittings are allowed.
5. Non-metallic services shall be entwined (min. three turns) with 18 gauge insulated copper wire, green in color, for the full length, with the end left above finished grade.
6. If the backfill height above the top of the main is equal to or greater than 12', the first section of service connection pipe shall be a standard length of approved cast iron or ductile iron pipe.
7. Laterals that are tunneled or trenched under existing curb and gutter or other utilities shall be backfilled within 2' of the crossing with CLSM, see Std. Dwg. GP300.
8. An "S" shall be stamped on top of new curb, where lateral crosses under curb.
9. The upper end of the service connection pipe shall be 6' deep, from the flow line to top of curb or finished ground service, unless otherwise approved by City Engineer.
10. Trenches shall not be backfilled until approved by City Engineer, see Std. Dwg. GP300.
11. All sanitary sewer services shall extend three (3) ft. beyond R/W line. If CUE exists, extend three (3) ft. beyond interior easement line.

The selection and use of this standard drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user.

Designed By:	STAFF
Drawn By:	KJD
Checked By:	MPT
Approved:	JMC



CITY OF GRANTS PASS
 101 Northwest 'A' Street
 Grants Pass, OR 97526
 (541) 450-6060 ph (541) 476-9218 fax

No.	Date	Revisions	App. By

NEW SEWER SERVICE CONNECTION

2018

DWG. NO. GP304