



Residential Energy Additional Measure Selection

Department of Consumer and Business Services

Building Codes Division

1535 Edgewater NW, Salem, Oregon

Mailing address: P.O. Box 14470, Salem, OR 97309-0404

503-373-1210 • Fax: 503-378-3656

Web: bcd.oregon.gov

RESIDENTIAL INFORMATION

Date: _____ Building permit number: _____

Owner's name: _____

Job address: _____

City: _____ State: _____ ZIP: _____

INSTRUCTIONS

Please select type of construction below; sign, date, and complete the entire form. Submit this form with your permit application or your project will be placed on hold until the required information is provided.

New construction. All conditioned spaces within residential buildings must comply with Table N1101.1(1) and two additional measures (one numbered and one lettered) from Table N1101.1(2) on page 2.

Additions. Additions to existing buildings or structures may be made without making the entire building or structure comply if the new additions comply with the requirements of this chapter. (N1101.3)

Large additions. Additions that are equal to or more than 40 percent of the existing building heated floor area or 600 square feet (55 m²) in area, whichever is less, must comply with Table N1101.1(2) on page 2. (N1101.3.1) *(Note: You must select one numbered **and** one lettered measure.)*

Small additions. Additions that are less than 40 percent of the existing building heated floor area or less than 600 square feet in area, whichever is less, must select one measure from Table N1101.1(2) on page 2 or comply with Table N1101.3 below. (N1101.3.2)

Exception: Additions that are less than 15 percent of existing building heated floor area or 200 square feet (18.58 m²) in area, whichever is less, are not required to comply with Table N1101.1(2) or Table N1101.3.

Selected item number: _____ **Selected item letter:** _____
Note: Depending on which Additional Measures you have selected, there may be sub-options that you will have to specify. Check the appropriate box if provided.

Applicant's signature: _____ Print name: _____

TABLE N1101.3 – SMALL ADDITION ADDITIONAL MEASURES (SELECT ONE)

<input type="checkbox"/>	1	Increase the ceiling insulation of the existing portion of the home as specified in Table N1101.2.
<input type="checkbox"/>	2	Replace all existing single-pane wood or aluminum windows to be U-value as specified in Table N1101.2.
<input type="checkbox"/>	3	Insulate the floor system as specified in Table N1101.2 and install 50 percent of permanently installed lighting fixtures as CFL or linear fluorescent or min. efficacy of 40 lumens per watt as specified in Section N1107.2.
<input type="checkbox"/>	4	Test the entire dwelling with blower door and exhibit no more than 7.0 air changes per hour @ 50 Pascals.
<input type="checkbox"/>	5	Seal and performance test the duct system.
<input type="checkbox"/>	6	Replace existing 78 percent AFUE or less gas furnace with a 92 percent AFUE or greater system.
<input type="checkbox"/>	7	Replace existing electric radiant space heaters with a ductless mini-split system with a minimum HSPF of 8.5.
<input type="checkbox"/>	8	Replace existing electric forced air furnace with an air source heat pump with a minimum HSPF of 8.5.
<input type="checkbox"/>	9	Replace existing water heater for a natural gas/propane water heater with a minimum EF of 0.67.
<input type="checkbox"/>	10	Install a solar water heating system with a minimum of 40 square feet of gross collector area.

**TABLE N1101.1(2)
ADDITIONAL MEASURES**

Envelope Enhancement Measures (Select One)	1	High efficiency walls Exterior walls—U-0.045/R-21 cavity insulation + R-5 continuous
	2	Upgraded features Exterior walls—U-0.057/R-23 intermediate or R-21 advanced, Framed floors—U-0.026/R-38, and Windows—U-0.28 (average UA)
	3	Upgraded features Exterior walls—U-0.055/R-23 intermediate or R-21 advanced, Flat ceiling ^e —U-0.017/R-60, and Framed floors—U-0.026/R-38
	4	Super Insulated Windows and Attic OR Framed Floors Windows—U-0.22 (Triple Pane Low-e), and Flat ceiling ^e —U-0.017/R-60 or Framed floors—U-0.026/R-38
	5	Air sealing home and ducts Mandatory air sealing of all wall coverings at top plate and air sealing checklist ^f , and Mechanical whole-building ventilation system with rates meeting M1503 or ASHRAE 62.2, and All ducts and air handlers contained within building envelope ^d or All ducts sealed with mastic ^b
	6	High efficiency thermal envelope UA^g Proposed UA is 8% lower than the code UA
Conservation Measure (Select One)	A	High efficiency HVAC system^a Gas-fired furnace or boiler AFUE 94%, or Air source heat pump HSPF 9.5/15.0 SEER cooling, or Ground source heat pump COP 3.5 or Energy Star rated
	B	Ducted HVAC systems within conditioned space All ducts and air handlers contained within building envelope ^d <i>Cannot be combined with Measure 5</i>
	C	Ductless heat pump Ductless heat pump HSPF 10.0 in primary zone of dwelling
	D	High efficiency water heater^c Natural gas/propane water heater with UEF 0.85 OR Electric heat pump water heater Tier 1 Northern Climate Specification Product

For SI: 1 square foot = 0.093 m², 1 watt per square foot = 10.8 W/m².

- a. Appliances located within the building thermal envelope shall have sealed combustion air installed. Combustion air shall be ducted directly from the outdoors.
- b. All duct joints and seams sealed with listed mastic; tape is only allowed at appliance or equipment connections (for service and replacement). Meet sealing criteria of Performance Tested Comfort Systems program administered by the Bonneville Power Administration (BPA).
- c. Residential water heaters less than 55 gallon storage volume.
- d. A total of 5 percent of an HVAC system's ductwork shall be permitted to be located outside of the conditioned space. Ducts located outside the conditioned space shall have insulation installed as required in this code.
- e. The maximum vaulted ceiling surface area shall not be greater than 50 percent of the total heated space floor area unless vaulted area has a U-factor no greater than U-0.026.
- f. Continuous air barrier. Additional requirement for sealing of all interior vertical wall covering to top plate framing. Sealing with foam gasket, caulk or other approved sealant listed for sealing wall covering material to structural material (example: gypsum board to wood stud framing).
- g. Table N1104.1(1) Standard base case design, Code UA shall be at least 8 percent less than the Proposed UA. Buildings with fenestration less than 15 percent of the total vertical wall area may adjust the Code UA to have 15 percent of the wall area as fenestration.